Inspectorate America Corp 178 Mortland Road Searsport, Maine 04974 (207)548-6440



NICHE EN COLLAND

QUALITY CERTIFICATE

Vessel SHORE TANK NO. 1 Customer **SPRAGUE**

Date

Port

SEARSPORT, MAINE

Report

SP/06/0215

Operation

ANALYSIS

Terminal

February 20, 2006 SPRAGUE

Reference V-06-00236

Sample # 31431

Name of material being tested Description of sample source Samples Drawn by (company) Samples Tested by (company) **NO. 6 FUEL OIL 0.5%**

EX. SHORE TK NO. 1 AFTER DISCHARGE OF CARIBBEAN **INSPECTORATE INSPECTORATE**

| Tests being Performed | Test method | Minimum | Maximum | Sample Source |
|--|---------------------------------|--------------|--------------|---------------|
| | | | | |
| | | | | |
| GRAVITY, API @ 60 F | ASTM D 4052 | | | 13.5 |
| FLASH POINT, F | ASTM D 93 | | | 208 |
| VISCOSITY, SSF @ 122 F | ASTM D 445/2161 | | | 110.2 |
| POUR POINT, F | ASTM D 97 | · | | +50.0 |
| WATER & SEDIMENT, % VOL. | ASTM D 1796 | | | 0.10 |
| SULPHUR, % WT. | ASTM D 4294 | | | 0.443 |
| 3H, % WT. | ASTM D 482 | | | 0.07 |
| NADIUM, PPM | AA/AE | | | 10 |
| SODIUM, PPM | AA/AE | | | 15 |
| BTU'S/POUND | CALCULATION | | | 18,623 |
| BTU'S/GALLON | CONVERSION | | | 151,349 |
| NITROGEN, % WT. | ASTM D 5762 | | | 0.3745 |
| CARBON RESIDUE, % WT. | ASTM D 4530 | | | 7.59 |
| ASPHALTENES, % WT. | IP-143 | | | 1.28 |
| 7 (6) (1) (1) (1) | | | | |
| | | | | |
| | | | | |
| | | | | |
| SPRAGUE PROVIDES THE ATTACHED INSPECTION REPORT/ANALYSIS | | | | |
| TERMINAL IN TANK ON THE DATE OF INSPECTION NOTED ON THE CERTIFICATE. THIS ANALYSIS IS PROVIDED TO THE CUSTOMER FOR THE PURPOSE OF | | | | |
| | | | | |
| | | | | |
| ESTABLISHING THE INDEPENDENTLY VERIFIED PR A COMPOSITE BASIS IN SPRAGUE'S TERMINAL SHO | ODUCT SPECIFICATION ON | | | |
| CERTIFICATE. THE INSPECTION REPORT IS NOT TO | THE LIGHT FOR ANY OTHER | | | |
| PURPOSE. SPRAGUE DISCLAIMS ANY LIABILITY FO. | R THE PRODUCT AFTER DELIVERY | | | |
| BY SPHAGUE TO CUSTOMER, SPRAGUE DISCLAIM | S ANY WARRANTY OF | | | |
| MERCHANTABILITY OR FITNESS FOR AN INTENDED US | E EXCEPT AS MAY BE SPECIFICALLY | | | |
| SET FORTH IN WRITING IN ANY CONTRACT OR TER AND A BUYER OF PRODUCT. SPRAGUE ASSUMES NO | HARILITY FOR CLAIMS OR LOSSES | | | |
| THAT MAY ARISE FROM CUSTOMER'S USE OF THIS | INSPECTION REPORT/ANALYSIS | | | |
| | - inv(r as as not reprint) | | | |
| | | | | |
| | | 1 | <u> </u> | |

DENNIS E. CURTIS

Inspectorate America Corp (Searsport, Me.)